

Region of Waterloo Public Health

99 Regina Street S, 3rd Floor, Waterloo ON N2J 4V3

Phone Number: (519) 575-4400

Fax Number: (519) 883-2226

PUBLIC POOL INSPECTION REPORT

Facility Inspected: TEST Class B Pool	Facility #: FAC--95060
Primary Owner:	Inspection #: INS-071-17045
	Inspection Date: 10-Aug-2018
	Inspected By:
Site Address: 99 Regina street south Waterloo ON	Facility Type: Indoor - Swimming Pool Class B
	Inspection Type: Required
	Inspection Reasons: Compliance Inspection
	Risk Rating: High
	Violations: 0

N/O = Not Observed at Time of Inspection N/A = Not Applicable YES = In Compliance NO = Not in Compliance

Indoor - Swimming Pool Class B

Operation

1. Results of any inspection conducted by a public health inspector are posted in accordance with the inspector's request YES
2. Water facility inaccessible when closed YES
3. Pool operator designated and trained in public pool operation, maintenance, filtration systems, water chemistry and all relevant safety and emergency procedures YES
4. Pool, deck, equipment, sanitary facility and adjoining areas kept in a safe and sanitary manner and free from hazards
5. Foot sprays are maintained in good working order and kept sanitary
6. Water clarity satisfactory/black disc clearly visible 9m away
7. Black disc (150 mm in diameter) on white background affixed to bottom of pool at its deepest point YES
8. Exposed piping within pool enclosure/equipment room is properly colour-coded YES
9. All components of the filtration, recirculation, and chemical feed systems are in continuous operation and maintained in proper working order
10. Accurate and functioning make-up water meter present
11. Moveable equipment (i.e. portable diving stands, starting platforms, swing ropes) on deck only when in use under supervision
12. Ladders and diving board/ platform are secure and have non-slip surface finish
13. Diving platform 3m or greater in height above the water is appropriately equipped
14. Locked gate preventing access to diving platform 3 m or greater when not in use

Water Chemistry

15. Sufficient supply and storage of chemicals and testing devices
16. Sanitizer levels in compliance
17. pH is within range of 7.2 to 7.8
18. Total alkalinity between 80mg/L (80ppm) and 120mg/L (120ppm)
19. Cyanuric acid is not greater than 60mg/L (60ppm)
20. Gas chlorine (Cl) handled properly, safety equipment present and chlorinating equipment operational

Facility Contact: Jennifer Toews
 Facility Address: 99 Regina street south, Waterloo ON

Gas chlorine (Cl) handled properly safety equipment present and chlorinating equipment

Record Keeping

- 21. Manual chemical testing in compliance
- 22. Daily records completed, signed and maintained YES
- 23. Other records signed and completed YES

Safety

- 24. Emergency telephone is present and operational
- 25. Written emergency, and operational procedures & instructions available at the pool
- 26. Premises is operated and maintained free from every condition that may be a potential/immediate health hazard

Safety Equipment

- 27. Outlet covers are secure and inspected at least once every 30 operating days
- 28. Safety equipment available and in good repair
- 29. Provide fully supplied first aid kit

Signs

- 30. Where there is a permanent spectator gallery adjacent to the deck, a notice forbidding spectators from walking upon the deck within 1.80 metres of the edge of the pool
- 31. Depth markings present in appropriate locations
- 32. "Pool Rules" notices displayed with complete information
- 33. Shower signs posted at each shower and every entrance to the deck used by bathers
- 34. Shallow Water/No Diving Caution (pool water depth < 2.5 m)
- 35. Class B Pool diving board - the sign "DANGER - AVOID DEEP OR LONG DIVES" in letters at least 150 mm high visible to divers
- 36. Class B Pool - Safety supervision signs conspicuously posted in letters at least 25 mm high
- 37. Pool Ramp Notices posted appropriately
- 38. Ramp(s) adjacent to the pool wall are provided with removable barriers that separate the walkway/ramp from the deck

Safety Supervision

- 39. Pool is able to increase rate of water turnover to comply with Class A pool
- 40. Safety supervision requirements met for Class B pool operating as a Class A pool
- 41. Admission standards

Closing Comments:

thgis is a test

I have read and understood this report:

Anne Shirley

Jennifer Toews, BSc, MPH